



INSTRUCTIONS FOR EXHIBITORS, SERVICE PROVIDERS AND STAND CONSTRUCTORS

At least one fire extinguisher (ABC 6 kg) and one fire blanket (complying with DIN EN 1869 standard) should be kept available at all times.

Furthermore, flammable materials may not be kept in the immediate vicinity of the exhibit.

All floors and rear/side walls in the direct vicinity of the exhibit must be made of non-flammable materials.

Exhibits featuring open flames may not be placed directly at the edge of stands.

Please consult the DECHEMA Ausstellungs-GmbH with regard to the required positioning within the stand area.

Use of flammable liquids

The use of flammable liquids requires a permit and must be submitted by completing the "Use of Flammable Liquids - Permit Application" form by **10 April 2024**.

Use of liquid gas or other gases

The use of liquid gas or other gases in compressed gas cylinders or cans also requires a permit and must be submitted by completing the form "Set up of Compressed and Liquid Gas Cylinders -" Permit Application" form by **10 April 2024**.

Daily requirement of flammable liquids

When using compressed gases, liquid gases or flammable liquids, please be sure to also refer to item 5.7. et seq. of the Technical Regulations.

Only the daily requirement of compressed gases, liquid gases or flammable liquids may be stored at the stand. Empty containers that have contained compressed gases, liquid gases or flammable liquids, shall not be kept or stored on stands or in exhibition halls.

For suitable storage facility please contact Messe Frankfurt's Logistics Services

logistics@messefrankfurt.com. They will provide appropriate storage space at exhibitor's expense.



Please upload at
www.achema.de/exhibitorportal

Login see stand confirmation

Hall _____ Stand _____

Company _____

Deadline 10 April 2024

For inquiries: safety@dechema.de

Phone +49 69 7564-655

1. Type of liquid:

2. Purpose:

3. Where will the containers be kept (exact position on the stand)?

The exhibitor must label the container position with a warning sign „flame hazard“ according to ASR A1.3 and DIN EN ISO 7010 being visible from outside.

4. Amount required per day: _____ piece _____ Content in kg or l

5. Are vapour/air mixtures or waste gases produced during processing?

no yes _____ daily filling

Supplies of combustible liquids sufficient for one day's operation and/or demonstration only may be stored on stands. Empty containers shall not be kept or stored on the stand.

For suitable storage facility please contact Messe Frankfurt's Logistics Service, logistics@messefrankfurt.com.

They will provide appropriate storage space at exhibitor's expense.

The stand was designed in compliance with the Technical Regulations (5.7.2).

Person to contact _____

E-mail _____

Phone _____

Mobile _____

Place / Date

Company stamp / Signature



Please upload at
www.achema.de/exhibitorportal

Login see stand confirmation

Hall _____ Stand _____

Company _____

Deadline 10 April 2024

For inquiries: safety@dechema.de

Phone +49 69 7564-655

1. Type of gas:

2. Purpose:

3. Where will the containers be kept (exact position on the stand)?

The exhibitor must label the container position with a warning sign „gas bottles hazard“ according to ASR A1.3 and DIN EN ISO 7010 being visible from outside.

4. Amount required per day: _____ pcs. _____ content in kg (liquid gas)
or l and P (compressed gas)

5. Is gas supplied via pipelines?

over a distance of _____ m in _____ pipes (type of pipe)

6. Built-in shut-off device:

Built-in shut-off device labelled: yes no
 yes no

7. Are vapour/air mixtures or waste gases produced during processing?

no yes _____ x daily filling

Only the requirements for one day's operation and demonstration may be kept at the stand. Storage of compressed and liquid gas cylinders is not permitted on the stand. For suitable storage facility please contact Messe Frankfurt's Logistics Service, logistics@messefrankfurt.com. They will provide appropriate storage space at exhibitor's expense.

The stand was designed in compliance with the Technical Regulations (5.7.1).

Person to contact _____ E-mail _____

Phone _____ Mobile _____

Place / Date

Company stamp / Signature